

P255-15605

ADDENDUM NUMBER 3

SHERMAN PARK  
BOYS AND GIRLS CLUB  
HVAC RENOVATION  
Site #791, Bldg. #2145  
3000 North Sherman Boulevard  
Milwaukee, WI 53210

Project Number: P255-15605

Notice Number: 7082

Date of Addendum: March 21, 2016

This Addendum to the Contract Documents is issued to modify, explain or correct the original documents, dated January 20, 2016, and is hereby made part of the Contract Documents. Acknowledge receipt of this Addendum in the space provided on the Bid Form, or bid may be rejected.

BIDDING, CONTRACT DOCUMENTS AND DRAWINGS

CONTRACTOR QUESTIONS

1. Is Thermal Solutions acceptable for condensing boiler?  
*RESPONSE: YES*
2. Is Griswold acceptable manufacturer for the side stream filter system?  
*RESPONSE: YES*
3. What is the operating temperature and pressure for the hot water system the side stream filter will be serving?  
*RESPONSE: 180 DEGREES AT 60 PSIG*
4. Does side stream filter system need to be ASME rated as specified? This will double cost and lead time.  
*RESPONSE: FILTER NOT REQUIRED TO BE ASME RATED.*
5. Specification for side stream filter notes 98% at 5 microns? This seems excessive.  
*RESPONSE: 90+% AT 40 MICRONS IS ACCEPTABLE*

BIDDING DOCUMENTS

Note: Bid date to remain March 23, 2016.

SPECIFICATIONS

23 52 34 – REVISE section 2.1 Manufacturers to include: Thermal Solutions

23 25 13 – REVISE section 2.4, A. Manufacturers to include: Griswold

23 25 13 – REVISE section 2.4, A. 3.a. and delete ASME Boiler and Pressure Vessel Code requirements.

23 25 13 – REVISE section 2.4, A. 10.a.3. to 90+% and 2.4, A. 10.a.5. to 40 microns

DRAWINGS

NO CHANGES

End of Addendum No. 3